

Annual Drinking Water Quality Report for 2025
P.O. Box 391
Croghan, New York 13327
Public Water Supply ID # 2402362

INTRODUCTION

To comply with State regulations, the Village of Croghan annually issues a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. EMERGENCY SITUATION PUBLIC NOTIFICATION IS BY RADIO, TELEVISION, ETC. Monitoring and sampling of the Croghan Water System is an ongoing process to assure safe potable water. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact The Village Garage at 315-346-1979 for more information. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Village Board meetings. The Village Board meets on the second Wednesday of each month at 6:00 p.m. at the Village office at 9578 Park Drive.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. State Health Department and FDA regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

Our water source is from two wells. Groundwater is drawn from a 34-foot deep and a 57-foot deep well. The water is disinfected with sodium hypochlorite as it is transferred to a 75,000-gallon storage tank. It then travels by gravity to you. The Village of Croghan owns the land around the wells and restricts activities therein. There are 352 metered water users receiving their water bills from the Village of Croghan. The Village of Croghan contracts to supply water to Beaver Falls via the Beaver Falls Water District. There are an additional 226 water users receiving their water bills through the Beaver Falls Water District.

AWQR SWAP Summary

The NYS DOH has evaluated this Public Water System's (PWS's) susceptibility to contamination under the Source Water Assessment Program (SWAP), and their findings are summarized in the paragraph below. It is important to stress that these assessments were created using available information and only estimate the potential for source water contamination. Elevated susceptibility ratings do not mean that source water contamination has or will occur for this PWS. This PWS provides treatment and regular monitoring to ensure the water delivered to consumers meets all applicable standards.

The source water assessment has rated these wells as having an elevated susceptibility to microbials, nitrates, industrial solvents, petroleum products, metals, and herbicides/pesticides. **This susceptibility is based on well yields or pumps drawing greater than 100 gpm from an unconfined aquifer and is unsupported by historical sampling information.** However, the New York State Department of Health will use this information to direct future source water protection activities.

A copy of the assessment can be obtained by contacting the supplier of water.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, is more than one year old.

It should be noted that all drinking water, including bottled drinking water, might be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the NYS Department of Health at the Watertown District Office (315-785-2277).

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picograms per liter (pg/l): Corresponds to one part per of liquid to one quadrillion parts of liquid (parts per quadrillion - ppq).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers that are longer than 10 micrometers.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Microbiological Contaminant -Total Coliform	No	Monthly	0	N/A	0	MCL=2 or more positive samples	Naturally present in the environment
Inorganic Contaminants -Fluoride	No	8/18	.2	ppm	N/A	MCL=2.2	Erosion of natural deposits; water additive that promotes strong teeth
-Nitrite	No	6/03	.17	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
PFOA	No	9/24	2.0	ng/l		10 ppt	
PFOS	No	9/24	1.92	ng/l		10ppt	
Dioxane	No	9/24	0.10	ug/l		1 ppb	
Nitrate	No	10/25	0.52	ppm	0	AL=10	Same as Nitrite
Copper (90 th %)	No	8/20	0.662	ppb	1300 15	AL=1300	Corrosion of household plumbing; erosion of natural deposits.
Lead (90 th %)	No	8/23	0.0011	ppb	N/A	AL=15	Same as Copper
Disinfection Byproducts Total	Crog MR	8/25	3.9	ppb	N/A	MCL=80	Byproduct of drinking water Chlorination
Trihalomethanes	B.F. MR	9/25	1.4	ppb	N/A	MCL=80	
Total Haloacetic Acids	Crog MR	8/25	ND	ppb	N/A	MCL=60	Same as above
	B.F. MR	9/25	ND	ppb		MCL=60	
Radioactive Contaminants					0		
Radium-226	No	9/23	0.200	pci/l	0	5	Decay of natural deposits; Manmade emissions
Radium-228	No	9/23	0.301	pci/l	0		Erosion of natural deposits
Gross Alpha	No	9/23	0.355	pci/l		15	

NOTES ON CHART Crog MR= Croghan Maximum Residence Time, B.F. MR= Beaver Falls Maximum Residence Time.

Lead and Copper: 90th percentile chart testing done August 2023* - Lead 0.0011, Copper 0.662.

*Notes: – The level presented represents the 90th percentile of the 6 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the Lead and Copper values detected at your water system.

WHAT DOES THIS INFORMATION MEAN?

The testing procedures for Lead and Copper sampling require that **first draw samples** be pulled and tested. Some of the factors that may distort or elevate test results are: previous days usage, amount of time since last draw, condition of household plumbing, etc. A rule of thumb is to let the drinking water faucet run a bit to flush out the potentially higher laden water. A lot can be said about keeping household plumbing updated.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2025, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements. We constantly test for various contaminants in the water supply to comply with regulatory requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

Why Save Water and How to Avoid Wasting It

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ♦ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ♦ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ♦ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using and by looking for ways to use less whenever you can. It is not hard to conserve water.

Conservation tips include:

- ♦ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ♦ Turn off the tap when brushing your teeth.
- ♦ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ♦ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons/year.

INFORMATION ON LEAD

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. *Village of Croghan* is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula.

Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact [\[Water Supply Name and Contact Information\]](#). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

INFORMATION ON LEAD SERVICE LINE INVENTORY

A Lead Service Line (LSL) is defined as any portion of pipe that is made of lead which connects the water main to the building inlet. An LSL may be owned by the water system, owned by the property owner, or both. The inventory includes both potable and non-potable SLs within a system. In accordance with the federal Lead and Copper Rule Revisions (LCRR) our system has prepared a lead service line inventory and have made it publicly accessible by visiting our website at: www.croghanny.org

Closing

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

The Croghan Village Board